

Overtime Report April 13th - May 11th 2022

Operator	Date	Time	OT Hrs.	Alarm Call	Operator Response
John	4/13/2022	3:27	1	Surge tank level low alarm.	Logged in remotely and acknowledged the alarm. Both Fuzzy Filters in the wash cycle and the surge tank level at 1.1ft. The settling pond wet well level at 4.0ft most likely some sludge carry over caused both filter to go into a wash. Shut down the filters and SAF unit.
John	4/23/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.
John	4/24/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.
John	4/29/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.
John	4/30/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.
John	5/1/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.
John	5/6/2022		2		Discharging to Atascadero Creek. Weekend sampling and lab analysis, creek observations, setting flow rate, recording discharge meter, logging data.